



Heater: 208VAC,10.5 amps. Turned on by 24 VDC relay. 24 VDC relay turned on by 5VDC (BS2).

Pump1,2,3: 230 VAC10 amp. Turned on by 24 VDC relay. 24 VDC relay turned on by 5VDC (BS2).

Valve1,2,3: 12 VDC turned on by 5VDC (BS2)

Re-circulation pump: 110 VDC turned on by 5VDC (BS2).

